



2018/19 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

School District Information		Health Authority (HA) Information	
SD No.	83	Region	Interior Health
SD Name	North Okanagan-Shuswap	Contact Name	Gordon Moseley
SD Contact Name:	Trevor Bettcher	Contact Phone	250-549-5725
SD Contact Phone:	250-804-7894	Report Submitted to HA	Yes
Report Date	March 30, 2019	Report Submission Date	March 30, 2019

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN		ADDITIONAL INFORMATION		
Ministry Facility Code	School Facility Name	Year Built	Testing Required	If no, describe why	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Ministry Submission Period
8389013	Carlin Elementary-Middle	2000	No		Nov-18	2	Water Fountain	By Room 17	0.001	No				30-Mar-19
8389013	Carlin Elementary-Middle	2000	No		Nov-18	2	Water Fountain	By Room 17	0.000	No				30-Mar-19
8389013	Carlin Elementary-Middle	1951	Yes		Nov-18	2	Sink	Room 9/ Staff Room	0.000	No				30-Mar-19
8389013	Carlin Elementary-Middle	1951	Yes		Nov-18	2	Sink	Room 9/ Staff Room	0.000	No				30-Mar-19
8389013	Carlin Elementary-Middle	1951	Yes		Nov-18	2	Water Fountain	By room 8	0.001	No				30-Mar-19
8389013	Carlin Elementary-Middle	1951	Yes		Nov-18	2	Water Fountain	By room 8	0.000	No				30-Mar-19
8389013	Carlin Elementary-Middle	2000	No		Nov-18	2	Water Fountain	Room 19	0.000	No				30-Mar-19
8389013	Carlin Elementary-Middle	2000	No		Nov-18	2	Water Fountain	Room 19	0.000	No				30-Mar-19
8389013	Carlin Elementary-Middle	2000	No		Nov-18	2	Water Fountain	Room 22	0.000	No				30-Mar-19
8389013	Carlin Elementary-Middle	2000	No		Nov-18	2	Water Fountain	Room 22	0.000	No				30-Mar-19
8389013	Carlin Elementary-Middle	1994	Yes		Nov-18	2	Sink	Kitchen/ By Gym	0.000	No				30-Mar-19
8389013	Carlin Elementary-Middle	1994	Yes		Nov-18	2	Sink	Kitchen/ By Gym	0.001	No				30-Mar-19
8389013	Carlin Elementary-Middle	1958	Yes		Nov-18	2	Sink	Room 28/ Science Room	0.001	No				30-Mar-19
8389013	Carlin Elementary-Middle	1958	Yes		Nov-18	2	Sink	Room 28/ Science Room	0.000	No				30-Mar-19
8399184	Gateway Community Learning	1993	No		Dec-18	2	Sink	Room 104	0.002	No				30-Mar-19
8399184	Gateway Community Learning	1993	No		Dec-18	2	Sink	Room 104	0.000	No				30-Mar-19
8399184	Gateway Community Learning	1993	No		Dec-18	2	Sink	Room 100	0.006	No				30-Mar-19
8399184	Gateway Community Learning	1993	No		Dec-18	2	Sink	Room 100	0.001	No				30-Mar-19
8399184	Gateway Community Learning	1993	No		Dec-18	2	Sink	Room 116	0.001	No				30-Mar-19
8399184	Gateway Community Learning	1993	No		Dec-18	2	Sink	Room 116	0.027	Yes	Building currently closed		1 min later/Building not occupied	30-Mar-19
8399184	Gateway Community Learning	1993	No		Dec-18	2	Water Fountain	Room 110/Hallway	0.003	No			First water out of tap	30-Mar-19
8399184	Gateway Community Learning	1993	No		Dec-18	2	Water Fountain	Room 110/Hallway	0.001	No				30-Mar-19
8399184	Gateway Community Learning	1993	No		Jan-19	2	Sink	Room 116	0.010	No				30-Mar-19
8399184	Gateway Community Learning	1993	Yes		Jan-19	2	Sink	Room 116	0.002	No				30-Mar-19
8389032	Ranchero Elementary	1977	Yes		Nov-18	2	Water Fountain	Room 5/Gym	0.000	No				30-Mar-19
8389032	Ranchero Elementary	1977	Yes		Nov-18	2	Water Fountain	Room 5/Gym	0.001	No				30-Mar-19
8389032	Ranchero Elementary	1983	Yes		Nov-18	2	Water Fountain	East Hall	0.002	No				30-Mar-19
8389032	Ranchero Elementary	1983	Yes		Nov-18	2	Water Fountain	East Hall	0.001	No				30-Mar-19
8389032	Ranchero Elementary	1977	Yes		Nov-18	2	Water Fountain	Pod Fountain	0.005	No				30-Mar-19
8389032	Ranchero Elementary	1977	Yes		Nov-18	2	Water Fountain	Pod Fountain	0.001	No				30-Mar-19
8389032	Ranchero Elementary	1977	Yes		Nov-18	2	Sink	Staff Room	0.003	No				30-Mar-19
8389032	Ranchero Elementary	1977	Yes		Nov-18	2	Sink	Staff Room	0.000	No				30-Mar-19
8389032	Ranchero Elementary	1983	Yes		Nov-18	2	Sink	Room 10	0.005	No				30-Mar-19
8389032	Ranchero Elementary	1983	Yes		Nov-18	2	Sink	Room 10	0.001	No				30-Mar-19
8383041	Silver Creek Elementary	1982	Yes		Dec-18	2	Sink	Room 8	0.001	No				30-Mar-19
8383041	Silver Creek Elementary	1982	Yes		Dec-18	2	Sink	Room 8	0.000	No				30-Mar-19
8383041	Silver Creek Elementary	1982	Yes		Dec-18	2	Water Filling Station	West Hall	0.000	No				30-Mar-19
8383041	Silver Creek Elementary	1982	Yes		Dec-18	2	Water Filling Station	West Hall	0.000	No				30-Mar-19
8383041	Silver Creek Elementary	1982	Yes		Dec-18	4	Sink	Medical Room	0.051	Yes	Posted sign to run water before drinking		First water out of tap	30-Mar-19
8383041	Silver Creek Elementary	1982	Yes		Dec-18	4	Sink	Medical Room	0.001	No	Replaced Fixture		1 min later	30-Mar-19
8383041	Silver Creek Elementary	1976	Yes		Dec-18	2	Water Fountain	Pod East Wing	0.004	No				30-Mar-19
8383041	Silver Creek Elementary	1976	Yes		Dec-18	2	Water Fountain	Pod East Wing	0.001	No				30-Mar-19
8383041	Silver Creek Elementary	1982	Yes		Dec-18	2	Sink	Staff Room	0.009	No				30-Mar-19
8383041	Silver Creek Elementary	1982	Yes		Dec-18	2	Sink	Staff Room	0.000	No				30-Mar-19
8383041	Silver Creek Elementary	1982	Yes		Jan-19	4	Sink	Medical Room	0.060	Yes	Posted sign to run water before drinking		First water out of tap	30-Mar-19
8383041	Silver Creek Elementary	1982	Yes		Jan-19	4	Sink	Medical Room	0.001	No	Installing lead filter		1 min later	30-Mar-19
8389024	South Canoe Elementary	1971	Yes		May-18	4	Water Fountain	South Hall	0.010	Yes	Posted sign to run water before drinking		First water out of fountain	30-Mar-19
8389024	South Canoe Elementary	1971	Yes		May-18	4	Water Fountain	South Hall	0.001	No	Installed lead filter		1 min later	30-Mar-19
8389024	South Canoe Elementary	1970	Yes		May-18	2	Water Fountain	Mid Hall	0.001	No				30-Mar-19
8389024	South Canoe Elementary	1970	Yes		May-18	2	Water Fountain	Mid Hall	0.007	No				30-Mar-19
8389024	South Canoe Elementary	1956	Yes		May-18	6	Water Fountain	North Hall	0.001	No				30-Mar-19
8389024	South Canoe Elementary	1956	Yes		May-18	6	Water Fountain	North Hall	0.019	Yes	Posted sign to run water before drinking			30-Mar-19
8389024	South Canoe Elementary	1971	Yes		May-18	2	Water Fountain	Room 27/Staff Room	0.015	Yes	Posted sign to run water before drinking		First water out of fountain	30-Mar-19
8389024	South Canoe Elementary	1971	Yes		May-18	2	Water Fountain	Room 27/Staff Room	0.001	No			1 min later	30-Mar-19
8389024	South Canoe Elementary	1971	Yes		May-18	4	Water Fountain	South Hall	0.003	No			Retest after lead filter installed	30-Mar-19
8389024	South Canoe Elementary	1971	Yes		May-18	4	Water Fountain	South Hall	0.001	No			Retest after lead filter installed	30-Mar-19
8389024	South Canoe Elementary	1956	Yes		May-18	6	Water Fountain	North Hall	0.079	Yes	Installed Lead filter/Posted sign to run water before drinking		First water out of tap	30-Mar-19
8389024	South Canoe Elementary	1956	Yes		May-18	6	Water Fountain	North Hall	0.006	No			1 min later	30-Mar-19
8389024	South Canoe Elementary	1956	Yes		Jun-18	6	Water Fountain	North Hall	0.002	No			Retest after lead filter installed	30-Mar-19
8389024	South Canoe Elementary	1956	Yes		Jun-18	6	Water Fountain	North Hall	0.000	No			Retest after lead filter installed	30-Mar-19
8389024	South Canoe Elementary	1971	Yes		Sep-18	2	Water Fountain	Room 19/Library	0.005	No				30-Mar-19

